



City of Lambertville Fire District #1
Bureau of Fire Safety
 230 North Main Street
 Lambertville, N.J. 08530



Frank J Ur
 Fire Marshal

Fire Headquarters – 609-397-2084
Headquarters Fax – 609-397-4465

Application for Open Flame Safety Permit

N.J.A.C. 5:70-2.7(a) - Permits shall be required and obtained from the local enforcing agency for the activities specified in this section, except where they are an integral part of a process or activity by reason of which a use is required to be registered and regulated as a life hazard use. Permits shall always be kept in the premises designated therein and shall always be subject to inspection by the fire official.

FAILURE TO GET REQUIRED PERMIT MAY RESULT IN PENALTY PER N.J.A.C. 5:70-2.12(b)7. i & N.J.A.C. 5:70-2.12(b)7. ii

EVENT LOCATION INFORMATION				
Application Date:	Event Date:	Event Time:	Block:	Lot:
Location Name:		Location of Event/Work:		
Location Address:		Municipality	Zip Code	
Type of Event and Reason for Permit:				
The number of grills/appliances:		Fuel Type: • - Charcoal • - Wood • - Propane		
If propane, the number of tanks:		Size of Tanks (lbs.)		

APPLICANT INFORMATION			
Name:		Company/Organization:	
Address:	City:	State:	Zip:
Phone:	Cell Phone:	Email:	

SIGNATURE OF APPLICANT

I attest that the above information is correct and understand that an inspection will verify compliance with this document. Any false information or failure to comply with this permit and the minimum required codes can result in revoking the permit.

Print	Signature	Date
-------	-----------	------

FOR OFFICE USE ONLY:				
Type I	Cash	Check	Check Number	Tracking Number
Permit Assignment #:	Permit Description:		NJUCF Permit #:	
Permit Approved or Denied	Reason if denied		Local ID:	
Fire Official Signature:			Date:	

Make Checks Payable to the: Lambertville Fire District #1



City of Lambertville Fire District #1
Bureau of Fire Safety
 230 North Main Street
 Lambertville, N.J. 08530



Frank J Ur
 Fire Marshal

Fire Headquarters – 609-397-2084
Headquarters Fax – 609-397-4465

A permit application shall be submitted through the Fire Marshal’s Office for every event.

The Fire Official or designated representative may revoke the permit for failure to comply with the conditions of issuance or any violations of any New Jersey Fire Code provisions.

N.J.A.C. 5:70-2.7(f); The fire official, upon inspection, may deny or revoke a permit at any time; this can be due to failure to meet the permit conditions, unabated fire code violations, or unsafe conditions.

Fire Extinguisher Requirements:

- All cooking vendors shall supply their own fire extinguishers.
- All fire extinguishers shall comply with NFPA 10. With a valid dated inspection tag.
- The minimum size shall be a 2A:10BC. Typically, a 5lb fire extinguisher. **Kitchen type, BC Extinguishers, and 1A10BC extinguishers will not be acceptable.**
- Class K portable fire extinguishers are required for cooking with vegetables, animal oils, and fats.
- Class K portable fire extinguishers are required for cooking with solid fuel.
- Class K portable fire extinguishers are required for deep-fat fryers.

Propane Tank Requirements:

- Propane tanks shall be secured, prevent falling over.
- Propane tanks and equipment shall comply with NFPA 58.
- Propane tanks shall not be taken into buildings/tents.
- All appliances shall be listed and labeled and approved by the fire code official. **(No homemade appliances)**
- No vehicles shall be parked within 5 feet of tents or canopies.
- Barricades shall be provided to maintain 5 feet between the heat-producing appliance and the public.
- Propane tanks between 4 and 40 lbs. shall have an Overfill Protection Device for filling in NJ.
- Propane tanks shall be hydro tested every 12 years, and not dented or have comprising rust.
- The regulator shall be in good condition, and the relief valve shall face away from the public areas.
- All plastic-type protective caps shall be removed from all propane tanks before operating.
- Hoses shall not be frayed or cracked, and there shall not be any tape on the hose.
- Hoses shall not be covered with grease and shall not be swollen.
- Hoses shall not create a tripping hazard.

Miscellaneous

- Only approved lighter fluid shall be used for charcoal grills.
- “Sterno” warmers may be used provided the fuel containers are properly protected from being knocked over and if the fuel containers are properly enclosed within the warmer units.
- Any tents used shall be fire retardant/inherently fire resistant and bear a label identifying such.
- All appliances shall be listed and labeled and approved by the fire official. [No homemade appliances]

If a tent is being used, please ensure that a tent permit is not required